

TEST REPORT

Al Maha Ceramics SAOG

Report No: WD-R-260312-0674

Sample No: WD-S-260312-1148

Date of Report: 19/03/2026

Introduction: Further to the request received from **M/s. Al Maha Ceramics SAOG** dated on 12th March 2026, the sample of Tile was tested for the below parameters.

Sample Type : AL MAHA PORCELAIN TILE
Request Number : WD-Q-260312-0138
Sample Received Date : 12/03/2026
Date of Test : 12/03/2026-19/03/2026
Tested By : SC-Subcontract

General Information

Name of the Product : AL MAHA PORCELAIN TILE

Asbestos Content

Test method

USEPA 600/R-93/116; Method for the Determination of Asbestos in Bulk Building Material.

Sl. No.	Tested Mineral	Morphology and Color	Total Slide score	Result
1.	Tremolite asbestos (CAS No. 77536-68-6)	No straight to curved fibers and bundles observed	0	No known species of asbestos minerals are present
2.	Actinolite asbestos (CAS No. 77536-66-4)		0	
3.	Anthophyllite asbestos (CAS No. 77536-67-5)		0	
4.	Chrysotile asbestos (CAS No. 12001-29-5)	No wavy fibers observed	0	
5.	Amosite asbestos (CAS No. 12172-73-5)	No straight to curved, rigid fibers observed	0	
6.	Crocidolite asbestos (CAS No. 12001-28-4)		0	

Remark: None

Signed for and on behalf of Wimpey Laboratories LLC



Anandu VS
Section In charge Chemistry-Specialty

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the laboratory.

End of text-

